



LABORATORY ANALYTICAL REPORT

Client: Texas Water Development Board
Project: TWDB
Lab ID: C07071178-006
Client Sample ID: 1825201

Report Date: 08/17/07
Collection Date: 07/19/07 09:30
Date Received: 07/25/07
Matrix: Aqueous

Analyses	Result	Units	Qual	MCL/		Method	Analysis Date / By
				RL	QCL		
MAJOR IONS							
Alkalinity, Phenolphthalein as CaCO3	ND	mg/L		1		A2320 B	07/27/07 20:49 / bas
Alkalinity, Total as CaCO3	357	mg/L		1		A2320 B	07/27/07 20:49 / bas
Bromide	ND	mg/L		0.50		E300.0	08/06/07 23:39 / bt
Calcium	1.3	mg/L		0.5		E200.7	07/31/07 14:06 / ts
Chloride	23	mg/L		1		A4500-Cl B	07/26/07 14:39 / jl
Fluoride	0.3	mg/L		0.1		A4500-F C	07/27/07 13:16 / bas
Magnesium	ND	mg/L		0.5		E200.7	07/31/07 14:06 / ts
Nitrogen, Nitrate+Nitrite as N	ND	mg/L		0.1		E353.2	07/30/07 15:28 / ljl
Potassium	0.9	mg/L		0.5		E200.7	07/31/07 14:06 / ts
Silica	10.6	mg/L		0.1		E200.7	07/31/07 14:06 / ts
Sodium	194	mg/L		0.5		E200.7	07/31/07 14:06 / ts
Sulfate	41	mg/L		1		A4500-SO4 E	07/25/07 16:36 / zd
METALS - DISSOLVED							
Aluminum	4	ug/L		1		E200.8	08/08/07 00:17 / sml
Antimony	ND	ug/L		1		E200.8	08/08/07 00:17 / sml
Arsenic	ND	ug/L		1		E200.8	08/08/07 00:17 / sml
Barium	9	ug/L		1		E200.8	08/08/07 00:17 / sml
Beryllium	ND	ug/L		1		E200.8	08/08/07 00:17 / sml
Boron	226	ug/L		100		E200.7	07/31/07 14:06 / ts
Cadmium	ND	ug/L		1		E200.8	08/08/07 00:17 / sml
Chromium	ND	ug/L		1		E200.8	08/08/07 00:17 / sml
Cobalt	ND	ug/L		1		E200.8	08/08/07 00:17 / sml
Copper	ND	ug/L		1		E200.8	08/08/07 00:17 / sml
Iron	ND	ug/L		30		E200.7	07/31/07 14:06 / ts
Lead	ND	ug/L		1		E200.8	08/08/07 00:17 / sml
Lithium	16	ug/L		1		E200.8	08/15/07 23:33 / bws
Manganese	1	ug/L		1		E200.7	07/31/07 14:06 / ts
Molybdenum	ND	ug/L		1		E200.8	08/08/07 00:17 / sml
Selenium	ND	ug/L		1		E200.8	08/08/07 00:17 / sml
Strontium	51	ug/L		1		E200.8	08/08/07 00:17 / sml
Thallium	ND	ug/L		1		E200.8	08/08/07 00:17 / sml
Vanadium	ND	ug/L		1		E200.8	08/08/07 00:17 / sml
Zinc	ND	ug/L		1		E200.8	08/08/07 00:17 / sml
DATA QUALITY							
A/C Balance (± 5)	0.521	%		250		Calculation	08/08/07 11:20 / bws
Anions	8.63	meq/L		250		Calculation	08/08/07 11:20 / bws
Cations	8.54	meq/L		250		Calculation	08/08/07 11:20 / bws

Report Definitions: RL - Analyte reporting limit.
 QCL - Quality control limit.

MCL - Maximum contaminant level.
 ND - Not detected at the reporting limit.